



OUTAGES FOR 2011

Level A: Substation down

[Effect: All electricity to Midrand-Estates interrupted]

Foreseen	Date	Duration	Cause	Remedy
A1				
Unforeseen	Date	Duration	Cause	Remedy
A2.1	Monday, 16/05/2011 @17h35	00:15:00	Unknown - ESKOM	Communicate with ESKOM
A2.2	Saturday, 13/08/2011 @02:32	00:00:08	Unknown - ESKOM	Communicate with ESKOM
A2.3	Tuesday, 23/08/2011 @17:59	00:07:20	Unknown - ESKOM	Communicate with ESKOM
A2.4	Tuesday, 23/08/2011 @18:57	00:20:24	Unknown - ESKOM	Communicate with ESKOM
A2.5	Tuesday, 23/08/2011 @19:19	00:22:06	Unknown - ESKOM	Communicate with ESKOM
A2.6	Wednesday, 24/08/2011 @17:59	00:23:04	Unknown - ESKOM	Communicate with ESKOM
A2.7	Wednesday, 14/09/2011 @13h21	00:00:08	Planned Maintenance - ESKOM	Communicate with ESKOM
A2.8	Wednesday, 05/10/2011 @18h27	00:07:36	Unknown - ESKOM	Communicate with ESKOM



OUTAGES FOR 2011

Level B: Supply from a breaker at Substation interrupted

[Effect: Larger portion of an Estate without electricity]

Foreseen	Date	Duration	Feeder	Cause	Remedy
B1.1					
Unforeseen	Date	Duration	Feeder	Cause	Remedy
B2.1	Tuesday, 30/08/2011 @08h30	00:35:00	Midlands Feeder 1 Panel 2: Ext 37 - 40	Construction damage	Safety warning to transgressor
B2.2	Tuesday, 30/08/2011 @08h30	05:30:00	Midlands Feeder 1 Panel 2: Cell Towers	Construction damage	Safety warning to transgressor