



OUTAGES FOR 2013

Level A: Substation down

[Effect: All electricity to Midrand-Estates interrupted]

Foreseen	Date	Duration	Cause	Remedy
A1				
Unforeseen	Date	Duration	Cause	Remedy
A2.1				



OUTAGES FOR 2013

Level B: Supply from a breaker at Substation interrupted (5 Mini-Subs or more)

[Effect : Larger portion of an Estate without electricity]

Foreseen	Date	Duration	Feeder	Cause	Remedy
B1.1	Thursday, 02/05/2013	02:00:00	Midstream 1 & 2	Upgrade on ESKOM network	
B1.2	Wednesday, 18/12/2013	01:00:00	Midstream Feeder 2	Damaged Cable	Search cable fault
B1.3	Friday, 20/12/2013	01:00:00	Midstream Feeder 2	Damaged Cable	Repair cable
Unforeseen	Date	Duration	Feeder	Cause	Remedy
B2.1	Friday, 07/06/2013	03:50:00	Midlands Feeder 5	Damaged Cable	Repair cable
B2.2	Friday, 07/06/2013	03:00:00	Midlands Feeder 6	Damaged T-switch	Repair T-switch
B2.3	Tuesday, 17/12/2013	02:00:00	Midstream Feeder 2	Cable fault on feeder cable	Search cable fault